



## **PLEASE NOTE**

This document, prepared by the [Legislative Counsel Office](#), is an office consolidation of this regulation, current to May 1, 2006. It is intended for information and reference purposes only.

This document is *not* the official version of these regulations. The regulations and the amendments printed in the [Royal Gazette](#) should be consulted to determine the authoritative text of these regulations.

For more information concerning the history of these regulations, please see the [Table of Regulations](#).

If you find any errors or omissions in this consolidation, please contact:

Legislative Counsel Office  
Tel: (902) 368-4291  
Email: [legislation@gov.pe.ca](mailto:legislation@gov.pe.ca)

## CHAPTER O-1.01

### OCCUPATIONAL HEALTH AND SAFETY ACT

#### SCAFFOLDING REGULATIONS

Pursuant to section 46 of the *Occupational Health and Safety Act* R.S.P.E.I. 1988, O-1.01 Council made the following regulations:

1. (1) In these regulations
- |   | Definitions                            |
|---|--|
| (a) “Act” means the <i>Occupational Health and Safety Act</i> ;   | Act                                    |
| (b) “boatswain’s chair” means a seat attached to a suspended rope, designed to accommodate one person in a sitting position;  | boatswain's chair                      |
| (c) “bracket scaffold” means a scaffold consisting of a work platform supported by brackets attached to a structural wall;  | bracket scaffold                       |
| (d) “cantilevered scaffold” means a scaffold consisting of a work platform attached to components that extend out from a building or a structure;   | cantilevered scaffold                  |
| (e) “competent person” means a person who is  | competent person                       |
| (i) qualified because of that person’s knowledge, training and experience to do the assigned work in a manner that will ensure the health and safety of persons in the workplace, and               |  |
| (ii) knowledgeable about the provisions of the Act and the regulations that apply to the assigned work, and about potential or actual danger to health or safety associated with the assigned work; |  |
| (f) “crane supported work platform” means a work platform suspended from the cable of a hoist or crane;   | crane supported work platform          |
| (g) “fork-lift platform” means a work platform supported by an industrial lift truck;   | fork-lift platform                     |
| (h) “ladderjack scaffold” means a scaffold consisting of a work platform supported by one or more brackets that are attached to one or more ladders;  | ladderjack scaffold                    |
| (i) “light duty scaffold” means a scaffold designed to support a uniformly distributed load of not more than 366 kg/m <sup>2</sup> ;  | light duty scaffold                    |
| (j) “power operated elevating work platform” means a work platform elevated and lowered by means of a mechanical, hydraulic, pneumatic or other powered mechanism;                                  | power operated elevating work platform |

professional engineer	(k) “professional engineer” means a person who may, under the <i>Engineering Profession Act</i> R.S.P.E.I. Cap. E-8.1, engage in the practice of engineering;
pumpjack scaffold	(l) “pumpjack scaffold” means a scaffold consisting of a work platform supported by vertical poles and adjustable support brackets;
rated capacity	(m) “rated capacity” means, in respect of a scaffold, the maximum safe working load for the scaffold <ul style="list-style-type: none"> <li>(i) as determined by the manufacturer of the scaffold, if the scaffold is a manufactured scaffold, or</li> <li>(ii) as certified by a professional engineer;</li> </ul>
rolling scaffold	(n) “rolling scaffold” means a scaffold consisting of a work platform that is <ul style="list-style-type: none"> <li>(i) supported by wheels, and</li> <li>(ii) designed to be moved manually;</li> </ul>
roofing bracket	(o) “roofing bracket” means a bracket <ul style="list-style-type: none"> <li>(i) that is secured to a sloped roof, and</li> <li>(ii) to which a work platform is secured;</li> </ul>
safe surface	(p) “safe surface” means a surface at a workplace that <ul style="list-style-type: none"> <li>(i) has sufficient size and strength to adequately support a worker who falls on to the surface, and</li> <li>(ii) is sufficiently horizontal to prevent a further fall from the surface by a worker who has fallen on to the surface;</li> </ul>
scaffold	(q) “scaffold” means any temporary work platform and its supporting structure that is used to support workers and materials;
suspended scaffold	(r) “suspended scaffold” means a scaffold with a work platform suspended from and supported by components cantilevered out from a building or other structure, and includes a swingstage, a boatswain’s chair and a multi-point suspended scaffold;
swingstage	(s) “swingstage” means a scaffold with a work platform supported by suspension ropes that are parallel;
wooden carpenter’s portable bracket scaffold	(t) “wooden carpenter’s portable bracket scaffold” means a scaffold consisting of a work platform supported by a triangular wooden bracket attached to a structural wall which does not normally have another means of support;
work area	(u) “work area” means a location at the workplace at which a worker is, or may be required or permitted to be, stationed and includes a work platform;

(v) “work platform” means a temporary horizontal working surface that provides access to a work area and support to a worker at the work area. work platform

(2) Where there is an inconsistency between a provision of these regulations and a standard or a manufacturer’s specification incorporated by reference in these regulations, the provision of these regulations prevails to the extent of the inconsistency. Inconsistencies with incorporated standards

(3) A duty or requirement that is imposed on an employer or a worker under these regulations applies to a self-employed person, with such modifications as the circumstances require. (EC44/06) Self-employed person

**2.** (1) An employer shall ensure that a scaffold provided to a worker by the employer for the use of a worker Scaffold requirements

- (a) is not loaded in excess of its rated capacity;
- (b) is not erected, operated, used, dismantled or supplied at a workplace unless the employer has available for inspection at the workplace, the design specifications for the scaffold
  - (i) provided by its manufacturer, if the scaffold is a manufactured scaffold, or
  - (ii) certified by the professional engineer who certified the design of the scaffold pursuant to section 8; and
- (c) is not used to support a ladder or other structure or device for the purpose of increasing the working height of the ladder, or other structure or device.

(2) No employer shall provide for the use of a worker, and no worker shall use, a ladderjack scaffold or a wooden carpenter’s portable bracket scaffold. (EC44/06) Scaffold restrictions

**3.** (1) An employer shall ensure that any work platform of a scaffold provided by the employer for the use of a worker meets the requirements of this section. Work platform requirements

- (2) A work platform shall Design and construction
- (a) be designed, constructed and maintained to support four times the maximum load likely to be imposed on the work platform;
  - (b) be at least 458 mm in width; and
  - (c) be securely fastened in place by cleating or wiring or such other means of fastening as provides an equivalent level of safety so as to prevent movement.

(3) Where the surface area of a work platform is made of wooden planks, the wooden planks shall Surface area - wooden planks

- (a) be No. 2 grade or better spruce that are 51 mm thick rough and 254 mm wide rough;

- (b) be free of decay, large knots, splits, warps or other defects;
- (c) not be painted;
- (d) extend at least 152 mm and not more than 305 mm beyond the supporting members of the scaffold;
- (e) be laid flat with an overlap at each end of 305 mm with a plank in any adjoining work platform, with the centre of the overlap directly over a supporting member; and
- (f) be of the same length, if practical, where the work platform is linked with one or more other work platforms.

Surface area - other materials

(4) Where the surface area of a work platform is made of materials other than wooden planks, the work platform shall have strength as is equivalent to that of a work platform made of wooden planks that meet the requirements of subsection (3). (EC44/06)

Scaffolds- erected from ground or safe surface

**4.** Where an employer provides, for the use of a worker, a scaffold that is erected from the ground or other safe surface, the employer shall ensure that the scaffold

- (a) is erected plumb and level;
- (b) is constructed with vertical supports that
  - (i) rest on a firm footing that can support the maximum load of the scaffold without unsafe settlement or deformation, or
  - (ii) where there is no firm footing, rest on mud sills that prevent unsafe settlement, deformation or tipping;
- (c) is constructed of components that are secured to prevent lateral movement and
  - (i) has at least one tie for each
    - (A) 4.6 m vertical interval, and
    - (B) 6.4 m horizontal interval, and
  - (ii) has diagonal braces in both the vertical and horizontal planes of the scaffold;
- (d) is installed and constructed by a competent person to secure the scaffold against lateral movement where the scaffold is enclosed; and
- (e) is constructed of vertical supports and bearers that are no greater than 3 m apart. (EC44/06)

Metal scaffolds

**5.** An employer shall ensure that a metal scaffold provided by the employer for the use of a worker

- (a) is erected, used, maintained and dismantled in accordance with the manufacturer's specifications, or in accordance with a professional engineer's design that includes instructions on erection, use, maintenance and dismantlement;
- (b) notwithstanding clause 4(c), is braced diagonally in the vertical plane, at every level and on each side, and in the horizontal plane, at every 4.6 m;

- (c) has components that are securely fastened with locking mechanisms, as designed by the manufacturer or a professional engineer, both during erection and otherwise; and
- (d) is equipped with screwjacks where necessary to ensure that the scaffold is plumb and level. (EC44/06)

**6.** An employer shall ensure that every scaffold provided by the employer for the use of a worker

- (a) is capable of supporting at least four times the maximum load likely to be imposed;
- (b) has a safe means of access and egress; and
- (c) is provided with fittings and gear that comply with the manufacturer's specifications or a professional engineer's certification. (EC44/06)

**7.** (1) An employer shall ensure that every scaffold provided by the employer for the use of a worker is inspected by a competent person each day prior to use, and after any modification, for any defect, damage, deterioration or loosening that may affect its strength.

Inspection by  
competent person

(2) A person who inspects a scaffold pursuant to subsection (1) and who finds any defect, damage, deterioration or loosening referred to in that subsection shall report the finding to the employer for whom the inspection is made.

Report

(3) On receipt of a report concerning a scaffold made pursuant to subsection (2), an employer shall ensure that the scaffold is not used until it is repaired.

Repair

(4) An employer shall ensure the erection and dismantling of every scaffold provided by the employer for the use of a worker is supervised by a competent person. (EC44/06)

Erection and  
dismantling of  
scaffold

**8.** (1) An employer shall ensure the design of a scaffold provided by the employer for the use of a worker is certified by a professional engineer, before the scaffold is used by a worker, where

Requirement for  
professional  
engineer's  
certification

- (a) the scaffold is a pumpjack scaffold that is greater than 9.75 m in height, and has one or more supporting members that are not commercially manufactured for the purpose for which they are used;
- (b) the scaffold is a wooden scaffold that is greater than 9.75 m in height;
- (c) the scaffold is a suspended scaffold that
  - (i) has one or more supporting members that are not commercially manufactured for the purpose for which they are used, or
  - (ii) has two work platforms that are
    - (A) linked, or
    - (B) tiered on one suspended scaffold;

- (d) the scaffold is greater than 15 m above the foundation on which it is based;
- (e) the scaffold is a crane supported work platform with one or more supporting members that are not commercially manufactured for the purpose for which they are used;
- (f) the scaffold is a fork-lift platform with one or more supporting members that are not commercially manufactured for the purpose for which they are used;
- (g) an officer determines that extraordinary conditions, including, but not limited to, wind and elevation conditions, require a professional engineer's certified design to ensure the adequacy of the scaffold; or
- (h) the scaffold
  - (i) is not a commercially manufactured scaffold, and
  - (ii) is not a scaffold that an employer is otherwise required under this subsection to ensure that it has a design certified by a professional engineer.

Scaffold to comply with certified design

(2) Where the design of a scaffold is required to be certified by a professional engineer under subsection (1), the employer who provides the scaffold for the use of a worker shall ensure the scaffold is erected, used, maintained and dismantled in accordance with the certified design.

Professional engineer's certification

(3) Where the design of a scaffold is required to be certified by a professional engineer under subsection (1), an officer may request a professional engineer to certify that the scaffold has been erected and maintained in accordance with the certified design.

employer to pay for certification

(4) Where an officer makes a request under subsection (3), the employer shall be responsible to pay for the cost of the certification. (EC44/06)

Protection from falling objects

**9.** Where work for an employer is being performed

- (a) on a scaffold provided by the employer or by another employer; and
  - (b) above a work area to which access is not restricted,
- the employer providing the scaffold shall ensure that any workers having access to the work area are protected from the hazard of objects falling from the scaffold by
- (c) providing overhead protection;
  - (d) having any tool, material or equipment on the scaffold tied to the scaffold; or
  - (e) employing such other means that provide an equivalent level of safety to the provision of overhead protection. (EC44/06)

Scaffold stability and movement

**10.** (1) Where a worker is working for an employer from a scaffold provided by the employer or by another employer, the employer

providing the scaffold shall ensure that the scaffold is not moved horizontally while the worker is on the scaffold, unless the worker is protected against falling by a fall arrest system that complies with the Fall Protection Regulations (EC633/04).

(2) An employer who provides a scaffold for the use of a worker shall ensure that the scaffold is not moved horizontally while any unsecured tool, material or equipment is on the scaffold.

Unsecured tools

(3) Where an employer causes a scaffold to be erected or dismantled, the employer shall ensure that, during the erection or dismantling of the scaffold, no worker works from the scaffold unless

Work performed in scaffold being dismantled or erected

- (a) the work platform of the scaffold is designed and constructed or erected in accordance with the requirements of these regulations; or
- (b) the worker performing the work is protected by a means of fall protection that complies with the Fall Protection Regulations (EC 633/04).

(4) Where a free standing scaffold that is at least three times higher than its minimum base dimension is provided by an employer for the use of a worker, the employer shall ensure that the scaffold is equipped with

Free standing scaffold

- (a) guy wires or outrigger stabilizers that prevent tipping; or
- (b) such other means of support that provides an equivalent level of safety.

(5) An employer shall ensure that a scaffold is not used by a worker when there is a severe weather condition which may create a hazardous situation. (EC44/06)

Prohibition - use of scaffold

**11.** (1) An employer who provides a scaffold for the use of a worker shall ensure that access to otherwise inaccessible work platforms of the scaffold, that are up to 9 m above the ground or other safe surface, is provided by

Access to scaffolds - up to 9 m

- (a) end frames providing a ladder-like structure having horizontal members uniformly spaced at 30 cm on centre, or
- (b) a vertical or portable ladder, or stairway, attached to the scaffold.

(2) An employer who provides a scaffold for the use of a worker shall ensure that access to otherwise inaccessible work platforms of the scaffold, that are over 9 m above the ground or other safe surface, if any, is provided by

Access to scaffolds - over 9 m

- (a) a stairway erected for the full height of the scaffold,
- (b) an attached vertical ladder, with rest platforms at least every 9 m which are fully guarded except at the ladder location, or
- (c) end frames providing a ladder-like structure having horizontal members uniformly spaced at 30 cm on centre, and rest platforms at least every 9 m which are fully guarded except at the ladder location.

Climbing on scaffold	(3) No employer who provides a scaffold for the use of a worker shall allow the worker to climb the outside of scaffold frames between work platforms. (EC44/06)
Rolling scaffolds	<p><b>12.</b> (1) An employer who provides a rolling scaffold for the use of a worker shall ensure that the rolling scaffold</p> <ul style="list-style-type: none"> <li>(a) is equipped with <ul style="list-style-type: none"> <li>(i) working braking and locking devices that prevent movement of the scaffold, and</li> <li>(ii) a mechanism that, when applied, secures the wheels of the scaffold; and</li> </ul> </li> <li>(b) is assembled <ul style="list-style-type: none"> <li>(i) with diagonal bracing in the vertical plane, at every level and on each side, and in the horizontal plane, at every 4.6m, and</li> <li>(ii) from components that <ul style="list-style-type: none"> <li>(A) are designed by a manufacturer or a professional engineer, and</li> <li>(B) are securely fastened with locking devices, as designed by the manufacturer or a professional engineer for use with the components of the rolling scaffold.</li> </ul> </li> </ul> </li> </ul>
Braking and locking devices	(2) An employer who provides a rolling scaffold for the use of a worker shall ensure that the braking and locking devices and the securing mechanism referred to subsection (1) are applied prior to and while a worker is using the scaffold.
Movement of rolling scaffold	(3) An employer who provides a rolling scaffold for the use of a worker shall ensure that the rolling scaffold is not moved by a worker on an inclined surface unless adequate precautions are taken to prevent tipping, sliding, acceleration or any other dangerous or sudden movement. (EC44/06)
Pumpjack scaffold - compliance	<b>13.</b> (1) An employer who provides a pumpjack scaffold for the use of a worker shall ensure that the pumpjack scaffold complies with this section.
Metal pumpjack scaffold	<p>(2) A pumpjack scaffold made of metal</p> <ul style="list-style-type: none"> <li>(a) shall not be more than 13.7 m in height; and</li> <li>(b) shall be braced every 4.6 m, starting at the base of the scaffold.</li> </ul>
Wood supports	<p>(3) A pumpjack scaffold that includes one or more supports made of wood</p> <ul style="list-style-type: none"> <li>(a) shall not be more than 7.3 m in height; and</li> <li>(b) shall be braced every 3 m, starting at the base of the scaffold.</li> </ul>
Use of pumpjack scaffold	(4) An employer who provides a pumpjack scaffold for the use of a worker shall ensure that a pumpjack scaffold

- (a) is used only as a light duty scaffold; and
- (b) is not used by more than two workers at one time.

(5) An employer who provides a pumpjack scaffold for the use of a worker shall ensure that a pumpjack scaffold is erected, used, maintained and dismantled

Erection, use, etc. of  
pumpjack scaffold

- (a) according to the manufacturer's specifications; or
- (b) in accordance with a professional engineer's design that includes instructions on erection, use, maintenance and dismantlement.  
(EC44/06)

**14.** (1) Where a suspended scaffold that is commercially manufactured is provided by an employer for the use of a worker, the employer shall ensure it is erected, used, maintained and dismantled in accordance with the manufacturer's specifications.

Suspended scaffolds  
- commercially  
manufactured

(2) Where a suspended scaffold that is not commercially manufactured is provided by an employer for the use of a worker, the employer shall

Suspended scaffolds  
- not commercially  
manufactured

- (a) develop written procedures for its operation; and
- (b) ensure that the suspended scaffold is
  - (i) operated in accordance with written operating procedures developed by the employer under clause (a);
  - (ii) constructed, erected, used, operated, maintained and dismantled in accordance with a professional engineer's design that includes instructions on erection, use, maintenance and dismantlement; and
  - (iii) designed, constructed, erected, used, operated, maintained, inspected, monitored and dismantled in accordance with CSA Standard Z91-02, "Health and Safety Code for suspended equipment operations", as amended from time to time.

(3) An employer shall ensure that a suspended scaffold provided by the employer to a worker is suspended by at least two upper attachments that are placed so that the suspension ropes are parallel, unless the suspended scaffold is a boatswain's chair.

Suspension

(4) An employer shall ensure that a suspended scaffold provided to a worker is tied, during use,

Scaffold to be tied

- (a) to an outrigger; or
- (b) to a parapet clamp, where it is impractical to tie the scaffold to an outrigger.

(5) An employer shall ensure that a suspended scaffold provided by the employer to a worker is

Scaffold not in use

- (a) lowered to the ground; or
- (b) lashed to the building or other structure to which it is attached, when the scaffold is not in use.

Movement of scaffold	(6) An employer shall ensure that a suspended scaffold provided by the employer to a worker is not moved up or down by a worker during use if the work platform of the scaffold is more than 10% out of level.
Powered suspended scaffold	(7) Where a powered suspended scaffold is provided by an employer to a worker and the employer does not otherwise provide a safe means of egress to the powered suspended scaffold, the employer shall ensure that the powered suspended scaffold is equipped with a controlled descent device, other than a lifeline, for use in the event of a mechanical or power failure, that can <ul style="list-style-type: none"> <li>(a) be safely operated from the work platform; and</li> <li>(b) move the scaffold to a point of safe egress.</li> </ul>
Suspended scaffold - compliance	(8) An employer shall ensure that a suspended scaffold provided by the employer to a worker complies with subsections (9) to (19).
Power units	(9) Power units on a suspended scaffold shall be equipped with <ul style="list-style-type: none"> <li>(a) positive pressure controls; and</li> <li>(b) positive drives,</li> </ul> for raising and lowering the work platform.
Manually operated suspended scaffold	(10) A manually operated suspended scaffold shall be equipped with a hoisting mechanism that has a secondary locking device that is securely locked in a positive drive position.
Tiering of suspended work platforms	(11) Where two work platforms are tiered on one suspended scaffold, the upper platform shall have at least two independent means of support arranged so that the failure of one support will not result in the collapse of the upper platform.
Suspended scaffold - supporting members	(12) Subject to clause (19)(a), all supporting members of a suspended scaffold, including outriggers, parapet clamps, anchor points, parapet and work platforms shall be able to withstand four times the maximum load likely to be imposed on them.
Counterweights	(13) Counterweights on a suspended scaffold shall <ul style="list-style-type: none"> <li>(a) be securely attached to the outriggers;</li> <li>(b) consist of solid material; and</li> <li>(c) be of sufficient weight to counterbalance four times the rated capacity of the scaffold.</li> </ul>
Positive stop device on outrigger	(14) Where the outrigger of a suspended scaffold does not have an eye bolt, the outer end of the outrigger shall be equipped with a positive stop device that prevents the movement of the rope.
Maximum load imposed on outrigger	(15) The maximum load that may be imposed on the components of an outrigger on a suspended scaffold shall be <ul style="list-style-type: none"> <li>(a) printed on each component; or</li> </ul>

(b) otherwise accessible to the worker at the work area where the outrigger is located.

(16) An outrigger used in a suspended scaffold shall not be made of wood or include components made of wood. Prohibition of wood outrigger

(17) Any outrigger or parapet clamp used on a suspended scaffold shall be tied to an anchor point to prevent movement of the outrigger or parapet clamp. Outrigger or parapet clamp to be tied

(18) Where an outrigger on a suspended scaffold consists of more than one component, the components shall be fastened by at least two independent fastening systems to prevent the components from separating. Fastening of outrigger components

(19) A rope used to suspend a work platform shall Suspension rope

- (a) be able to withstand ten times the maximum load likely to be imposed on the rope;
- (b) where made of wire, be not less than 7.8 mm in diameter;
- (c) where made of polypropylene, be not less than 16 mm in diameter; and
- (d) in the case of a suspended scaffold that can be moved upward and downward,
  - (i) extend to the nearest safe surface, and
  - (ii) be secure from tangling or fouling.

(20) An employer shall ensure that a fall arrest system, including a ropegrab and an independent life line, is used by workers Fall arrest system

- (a) working on or from a suspended scaffold; and
- (b) entering onto or leaving a suspended scaffold.

(21) Notwithstanding subsection (20), where a suspended scaffold has more than one means of support on each side of the work platform, either of which would prevent collapse of the scaffold in the event of the failure of the other, an employer may attach a fall arrest system to an adequate anchor point on the platform. Exception

(22) Where a worker is performing work on a suspended scaffold, an employer shall ensure the work area below the work platform Work area below suspended scaffold

- (a) is roped off, barricaded or provided with a means of overhead protection; and
- (b) has highly visible warning signs posted to notify workers of the overhead hazard.

(23) An employer shall ensure that Protection of rope components

- (a) all suspension lines, tiebacks, lifelines and other supporting components of a suspended scaffold that are made of rope; and
- (b) the internal hoist mechanisms,

are protected from abrasions, corrosive substances, other foreign materials, heat or work activities that might damage the rope or the internal hoist mechanisms. (EC44/06)

- Bracket scaffold **15.** An employer who provides a bracket scaffold for the use of a worker shall ensure that a bracket scaffold
- (a) does not have brackets more than 3 m apart;
  - (b) is securely attached to the structural wall to prevent dislodging; and
  - (c) is erected, used, maintained and dismantled in accordance with
    - (i) the manufacturer's specifications, or
    - (ii) a professional engineer's design that includes instructions on erection, use, maintenance and dismantlement. (EC44/06)
- Roofing bracket **16.** An employer who provides a roofing bracket for the use of a worker shall ensure that a roofing bracket
- (a) is erected and maintained to support four times the maximum load that is likely to be imposed on the bracket;
  - (b) is securely nailed to the roof;
  - (c) has a span of no more than 3 m; and
  - (d) is erected, used, maintained and dismantled in accordance with
    - (i) the manufacturer's specifications, or
    - (ii) a professional engineer's design that includes instructions on erection, use, maintenance and dismantlement. (EC44/06)
- Use of industrial lift truck **17.** (1) An employer shall ensure that an industrial lift truck is not used to lift a fork-lift platform where
- (a) the ground or other conditions at a workplace may affect the stability of the industrial lift truck; or
  - (b) the industrial lift truck is susceptible to tipping, displacement or other destabilization.
- Fork-lift platform (2) An employer shall ensure that a fork-lift platform is
- (a) erected, used, maintained and dismantled in accordance with
    - (i) the manufacturer's specifications, or
    - (ii) a professional engineer's design that includes instructions on erection, use, maintenance and dismantlement;
  - (b) equipped with guardrails;
  - (c) securely attached to an industrial lift truck during use;
  - (d) operated at all times by a competent person, who shall be continuously at the controls where the platform is in an elevated position; and
  - (e) used only where a firm, flat surface ensures the stability of the industrial lift truck, unless otherwise specified by the manufacturer.

- (3) While a worker is working on a fork-lift platform, the employer of the worker shall ensure that the worker is wearing a fall arrest system and that the fall arrest system is attached to an anchor point on the platform. Fall arrest system
- (4) An employer shall ensure that an industrial lift truck complies with CSA Standard B335-04, "Safety standard for lift trucks". Application of CSA Standard
- (5) Where  
 (a) a fork-lift platform is in an elevated position; and  
 (b) a worker is on the platform,  
 the employer of the worker shall ensure the industrial lift truck supporting the work platform is not moved horizontally. (EC44/06) Horizontal movement of industrial lift truck
- 18.** (1) An employer who provides a cantilevered scaffold for the use of a worker shall ensure that the cantilevered scaffold is erected, used, maintained and dismantled in accordance with  
 (a) the manufacturer's specifications, or  
 (b) a professional engineer's design that includes instructions on erection, use, maintenance and dismantlement. Cantilevered scaffold - outrigger requirement
- (2) An employer shall ensure that a cantilevered scaffold is not used as a landing platform for loads deposited by a crane or hoist, unless  
 (a) fall protection is used by a worker using the scaffold; and  
 (b) a guardrail is placed at the entrance to the work platform when the work platform is not in use. Use of cantilevered scaffold
- (3) An employer who provides a cantilevered scaffold for the use of a worker shall ensure that the cantilevered scaffold is equipped with a fully decked work platform. (EC44/06) Requirement - fully decked work platform
- 19.** (1) An employer who provides a power operated elevating work platform for the use of a worker shall ensure that the work platform is equipped with  
 (a) positive pressure controls for the positioning of the work platform;  
 (b) a power elevating mechanism equipped with positive drives for both raising and lowering the work platform;  
 (c) an interlock device that limits lateral movement when the height of the work platform exceeds that specified by the manufacturer; and  
 (d) an elevating mechanism that, upon failure, locks the work platform in the elevated position. Power operated elevating work platform
- (2) Where an elevating mechanism referred to in clause (1)(b) of a power operated elevating work platform fails while a worker is working on the work platform, the employer who provided the work platform for the use of the worker shall ensure that the worker is removed from the work platform before Failure of elevating mechanism

- (a) the work platform is lowered; or
- (b) repairs are made to the elevating mechanism.

Communication

(3) Where the operator of a power operated elevating work platform is not the worker being raised on the work platform, the employer who provided the work platform for the use of the worker shall ensure that there is an effective and direct means of communication between the operator and the worker.

Application of CSA standards

(4) The owner of a power operated elevating work platform, and an employer who provides a power operated elevating work platform for the use of a worker, shall ensure that the power operated elevating work platform is designed, constructed, erected, maintained, inspected, monitored and used in accordance with the following CSA Standards, as applicable:

- (a) B354.1-04, "Portable Elevating Work Platforms";
- (b) B354.2-02, "Self Propelled Elevating Work Platforms";
- (c) B354.4-02, "Self Propelled Boom Supported Elevating Work Platforms";
- (d) CAN/CSA - Z271-98, "Safety Code for Suspended Elevating Platforms";
- (e) CSA C225-00, "Vehicle Mounted Aerial Device".

Operation requirements

(5) An employer who provides a power operated elevating work platform for the use of a worker shall ensure that

- (a) the worker is competent to operate the platform or that the platform is operated by another worker who is competent to do so; and
- (b) the worker operating the platform has available on the work platform
  - (i) a legible operator's manual, and
  - (ii) information on
    - (A) all of the applicable operational limitations and requirements, including those relating to the use of outriggers, stabilizers and extendable axles,
    - (B) the specific surface conditions required for safe use in the elevated position,
    - (C) such warnings as may be specified by the manufacturer;
    - (D) the name and number of the CSA Standard to which the power operated elevating work platform was designed, and
    - (E) the name and address of the owner of the work platform.

Posting of information

(6) An employer who provides a power operated elevating work platform for the use of a worker shall ensure that information on

- (a) the rated capacity of the work platform; and

(b) other than for a boom-type elevating work platform, the direction of the machine movement for each operating control of the work platform,  
is securely posted at the controls of the work platform.

(7) The owner of a power operated elevating work platform shall keep a permanent record of all inspections, tests, repairs, modifications and maintenance performed on it.

Record to be kept  
by owner

(8) The record required under subsection (7) shall include the name and signature of the person who performed the inspection, test, repair, modification or maintenance.

Content of record

(9) An employer who provides a power operated elevating work platform for the use of a worker shall ensure that the worker who operates the work platform has, before using it for the first time,

Instruction or  
training of operator

- (a) received oral or written instruction on the safe operation of the particular work platform; or
- (b) otherwise been adequately trained to operate the work platform.

(10) An employer shall ensure that the instruction and training required by a worker under subsection (9) is provided by a competent person and includes

Instruction and  
training  
requirements

- (a) instruction
  - (i) on the manufacturer's specifications,
  - (ii) on applicable load limitations,
  - (iii) on the kind of surfaces on which the power operated elevating work platform are designed to be used; and
- (b) a hands on demonstration of the proper use of all controls.

(11) An employer who provides a power operated elevating work platform for the use of a worker shall ensure that the work platform

Operation  
requirements

- (a) is not loaded in excess of its rated capacity;
- (b) is used on a firm, level surface unless otherwise specified by the manufacturer;
- (c) is used only in accordance with the manufacturer's specifications;
- (d) is not loaded and used in such a manner as to create an unstable condition or cause a hazard;
- (e) is not moved vertically or horizontally unless every worker on the scaffold, while it is being moved, is protected against falling by a fall arrest system that complies with the Fall Protection Regulations (EC633/04); and
- (f) is equipped with an emergency stop button.

(12) An employer of a worker who uses a power operated elevating work platform shall ensure that the worker is protected against falling by

Requirement for fall  
arrest system

a fall arrest system that complies with the Fall Protection Regulations (EC633/04). (EC44/06)

Crane or hoist suspended work platforms

**20.** (1) An employer shall not provide a crane supported work platform for the use of a worker unless the work to be performed by the worker cannot be done from a scaffold in a safe and practical manner.

Certification of hoist by professional engineer

(2) An employer who provides a crane supported work platform for the use of a worker shall ensure, where a hoist is used to suspend the work platform, that the design of the hoist is certified by a professional engineer before the work platform is suspended from the hoist.

Crane or hoist requirements

(3) An employer who provides a crane supported work platform for the use of a worker shall ensure that the crane or hoist used to suspend the work platform

- (a) is operational in the power up and power down positions;
- (b) is equipped with an automatic brake system that operates when the crane or hoist is not lifting or lowering;
- (c) is equipped with an anti-two block device;
- (d) is operated at a safe lifting and lowering speed; and
- (e) has at least three full wraps on the hoisting drum at all times.

Means of communication

(4) An employer who provides a crane supported work platform for the use of a worker shall ensure that the operator of the crane or hoist used to suspend the work platform has a constant means of communication with the worker on the work platform.

Crane supported work platform - secondary means of support

(5) An employer who provides a crane supported work platform for the use of a worker shall ensure that the work platform has a secondary means of support that is

- (a) shackled above the ball of the crane; and
- (b) able to support the platform if the primary means of support fails.

Commercially manufactured crane

(6) An employer who provides a commercially manufactured crane supported work platform for the use of a worker shall ensure that the work platform is erected, used, maintained and dismantled in accordance with the manufacturer's specifications.

Design of non-commercially manufactured platform

(7) An employer shall, before providing a crane supported work platform that is not commercially manufactured for the use of a worker, ensure that

- (a) the design of the work platform is certified by a professional engineer; and
- (b) the work platform is erected, used, maintained and dismantled in accordance with the certified design.

Use of fall arrest system

(8) An employer who provides a crane supported work platform for the use of a worker shall ensure that a fall arrest system, attached to an

anchor point on the work platform, is used by workers working from or otherwise present on the work platform. (EC44/06)

**21.** Except as expressly permitted in these regulations or in another enactment, an employer shall ensure that workers are not lifted or held aloft in equipment, such as loader buckets or backhoes, that is not specifically designed for that purpose. (EC44/06)

Lifting in certain  
equipment  
prohibited